

THE FOLLOWING ITEMS ARE CODE REQUIREMENTS FOR REROOFING.

- 1.** Only two (2) layers of asphalt shingles are permitted. R907.3
Roofing over wood shingles or shakes is not permitted.
- 2.** Provide ice dam protection on all roof edges. Protection shall extend from the eave's edge to a point at least 24" inside the exterior wall line. R905.2.7.1
- 3.** Attic ventilation (house) that equals one (1) square foot of ventilation for each 150 square feet of attic space shall be provided. 1square foot for every 300 square feet of attic area is allowed if half of the ventilation opening is in the top 1/2 of the roof. R806.3
- 4.** Sidewall Flashing: Flashing against a vertical sidewall shall be by the step-flashing method. R905.2.8.4
- 5.** Chimney Flashing. Flashing shall be inlet into the chimney and mortared or caulked in.
- 6.** Chimneys 18 inches or wider shall have crickets to divert the water around the rear of the chimney.

CALL CHAD SOMMER FOR FINAL INSPECTION @ 507-272-7109